

Recreation NB | Loisirs N.-B.

Standard Operating Procedures



SOP Usage Statement

The Standard Operating Procedures (SOP) provided by Recreation NB | Loisirs N.-B. are intended as guiding documents to support our members. Recreation professionals should always confirm with current legislation, regulations, and municipal/provincial mandates before using SOPs. These resources are designed to give municipalities and organizations a starting point, which can then be customized to fit their local context and support best practices. **Recreation NB | Loisirs N.-B. does not assume any liability for the use of these resources; they are provided solely as a reference to help guide local practices.**

SOP Frequency Legend

Frequency:	Description:
Daily	Task suggested daily
Weekly	Task suggested once per week
Monthly	Task suggested once per month
Quarterly	Task suggested once per every 3 months
Bi-Annual	Task suggested every six months
Annual	Task suggested once per year

SOP Categories

To make navigation easier, SOPs are organized into categories. Users can browse by area of operation:

- Maintenance / General Facility
- Ice / Arena Operations
- Mechanical / Electrical / HVAC
- Safety
- Equipment / Tools
- Technology / Systems

Updates & Revisions


Recreation NB | Loisirs N.-B. will review resources annually to ensure they reflect current best practices and member needs. New SOPs may be added and existing ones revised as regulations, standards, and facility practices evolve.

Questions or Support

For questions about these SOPs, or to share feedback and local adaptations that may benefit other members please contact:

Nicole Hebert

 nhebert@recreationnb.ca

 (506) 459 - 1929 ext. 2

Recreation NB | Loisirs N.-B.

Standard Operating Procedures



SOP RO System

Category:

Frequency: Weekly

Weekly inspection and operation of the Reverse Osmosis (RO) system to ensure proper water filtration and system performance. This includes checking pressure, flow rates, filters, valves, and overall system functionality, as well as documenting any maintenance needs.

Tasks

Steps	Type	Name / Description
1	Instruction	Health & Safety
Ensure all Best Practice Policies and Health and Safety Policies are adhered to when completing the following tasks. If at any point in the maintenance procedure where health and safety is in the question, STOP the procedure immediately and contact your supervisor before proceeding.		
2	Instruction	Inspect RO HWB 1
Verify power is in the 'ON' position on the controller. Verify power toggle switch on the burner is in the on position. Verify that no alarms are present on the burner controller. Note any alarms or faults, DO NOT RESET, please contact Director of Operations or Operations manager regarding any fault or failure.		
3	Instruction	Inspect RO HWB2
Verify power is in the 'ON' position on the controller. Verify power toggle switch on the burner is in the on position. Verify that no alarms are present on the burner controller. Note any alarms or faults, DO NOT RESET, please contact Director of Operations or Operations manager regarding any fault or failure.		
4	Instruction	Verify Exhaust System
Verify vent motor controllers are in the ON position.		
5	Instruction	Record Readings
Record readings in logbook.		
6	Instruction	Inspect for water leaks
Inspect all piping, valves, fittings, pumps, etc. for water leaks.		
7	Instruction	File Service Report in CMMS
File Service Report in CMMS when received. Report any damage, issues or parts required to your supervisor.		